


PUBLIC UTILITIES BOARD · SINGAPORE

PUB BUILDING, SOMERSET ROAD, SINGAPORE 0923. REPUBLIC OF SINGAPORE
TEL: 2358888 · CABLE ADDRESS: PIYUBI · TELEX: PUB RS 34793



Our Ref: WE 92413/47

Your Ref: PY/001/83

WATER

Department:

21 Jun 83

Technical Manager
Glasscoat Singapore Pte Ltd
70 Lorong Patong
Upper Serangoon Road
Singapore 1954

Attn: Mr Patrick Yee

Dear Sir

WHITE "GLASSFLAKE" FOR WATER STORAGE TANK

I refer to your letter dated 6 Jun 83.


2 I am pleased to inform you that your above product is approved for lining water storage tanks subject to the following conditions:

- a containers lined with white "Glassflake" shall be adequately cleaned and sterilized to remove unpleasant taste and odour imparted into the water and
- b there shall be no change in the nature and sources of ingredients, or in the process of manufacture of your product from the samples you submitted to SISIR on 10 Sep 82.

3 Although this product is approved, it will still be required to be similarly tested on a batch-by-batch basis by SISIR from time to time as and when considered necessary by this Department.

4 This Department reserves the right to withdraw its approval at any time for the said product without assigning any reason thereof.

Yours faithfully


CHAN CHOW TEING
for CHIEF WATER ENGINEER

cc (See attached)